

STATE OF VERMONT
PUBLIC SERVICE BOARD

Docket No. 7596

Petition of Central Vermont Public Service Corporation ("CVPS") for a Certificate of Public Good, pursuant to 30 V.S.A. Section 248, authorizing the reconstruction of the CVPS Hewitt Road substation in Bristol, Vermont, including (1) the replacement of structural steel; (2) replacement of an existing 46/12.47 kV 5.0/7.0 MVA transformer with a 7.5/10.5 MVA transformer; and (3) associated upgrades including oil containment, bus work, breakers with microprocessor-based relays, battery system, and a control house –)

and

Docket No. 7597

Joint Petition of Central Vermont Public Service Corporation ("CVPS") and Vermont Electric Power Company, Inc. ("VELCO"), for a Certificate of Public Good, pursuant to 30 V.S.A. Section 248, authorizing (1) the reconductoring of 3.9 miles of 46 kV transmission line in Middlebury and Weybridge, Vermont; (2) construction of a new 46 kV transmission line 5 miles in length in Weybridge and New Haven, Vermont; (3) expansion of the CVPS Hewitt Road substation, including the installation of a 46 kV 5.4 MVAR capacitor bank, in Bristol, Vermont; (4) installation of new substation breakers at the VELCO Middlebury substation in Middlebury, Vermont; and (5) installation of new substation breakers at the VELCO New Haven substation in New Haven, Vermont –)

Order entered: 9/8/2010

ORDER RE: APPROVAL OF OIL-CONTAINMENT PLAN

On August 20, 2010, the Public Service Board ("Board") issued an Order and two Certificates of Public Good ("CPG") approving, with conditions, (1) the reconstruction of the Central Vermont Public Service Corporation ("CVPS") Hewitt Road substation in Bristol, Vermont, and (2) the "Middlebury Reliability Project" proposed by CVPS and Vermont Electric Power Company, Inc. A condition of the Order stated:

Central Vermont Public Service Corporation ("CVPS") shall install a surface liner and temporary berm structure as an oil-containment measure for the temporary substation at the Hewitt Road substation site. Prior to commencement of construction for the temporary substation, CVPS shall file, for Board approval, a proposed plan for the oil-containment system. Parties shall have one week, from the date this plan is filed with the Board, to comment on the plan.¹

On August 25, 2010, CVPS filed a proposed plan for the oil-containment system for the temporary substation. On August 27, 2010, the Vermont Department of Public Service filed a letter stating that it finds CVPS's proposed plan to be satisfactory. No other party filed comments.

We hereby approve CVPS's proposed plan for the oil-containment system for the temporary substation at the Hewitt Road substation site.

SO ORDERED.

Dated at Montpelier, Vermont, this 8th day of September, 2010.

<u>s/ James Volz</u>)	
)	PUBLIC SERVICE
)	
<u>s/ David C. Coen</u>)	BOARD
)	
)	OF VERMONT
)	

OFFICE OF THE CLERK

FILED: September 8, 2010

ATTEST: s/ Susan M. Hudson
Clerk of the Board

NOTICE TO READERS: This decision is subject to revision of technical errors. Readers are requested to notify the Clerk of the Board (by e-mail, telephone, or in writing) of any apparent errors, in order that any necessary corrections may be made. (E-mail address: psb.clerk@state.vt.us)

Appeal of this decision to the Supreme Court of Vermont must be filed with the Clerk of the Board within thirty days. Appeal will not stay the effect of this Order, absent further Order by this Board or appropriate action by the Supreme Court of Vermont. Motions for reconsideration or stay, if any, must be filed with the Clerk of the Board within ten days of the date of this decision and order.

1. Order of 8/20/10 at 67, Condition 2(d). The same condition was repeated in the two CPGs.